

FIRE SAFETY CODE INSPECTION SHEET

“ESCAPE” GUIDE

Fire Safety and Code Enforcement Montgomery County Fire and Rescue Service

Contact: matthew.kelleher@montgomerycountymd.gov
240.777.2457

In the interest of Fire and Life Safety, Please review this fire safety code Inspection “ESCAPE” Guide Daily.

Exits: Unlocked, not blocked and proper signage

Storage: Clean, orderly and not excessive: no stock shall be stored closer than 18 inches below the plane of the deflector of any fire sprinkler head

Capacity: Does not exceed number on certificate; posted in a conspicuous location

Access/Aisles: Maintain 36 inch wide clear path to gas, electric, water shutoffs, and equipment; keep aisles free and clear at all times; provide 6 inch high address numbers that are easily visible from the street

Protection: Smoke detection, fire alarm, and automatic fire sprinkler systems are in proper working order and tested annually, with written documentation

Emergency Lighting: Working properly and tested every 30 days, with written documentation